FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS Additional Drawing No. (Alternative Form for Single Chamber, Completely Shop or Field Fabricated Vessels Only) As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1 Header Volume (cu.ft.) 1. Manufactured and certified by Harsco Industrial Air-X-Changers, 5615 South 129th E. Ave., Tulsa, Oklahoma, 74134 (Name and address of Manufacturer) 2. Manufactured for ARCHROCK SERVICES L.P. (f, P.O. BOX 690349, HOUSTON, 77269 (Name and address of Purchaser) 3. Location of Installation UNKNOWN (Name and address) 4. Type Heat Exchanger 15087401.1 1X-SEC REV 2 92259 2015 N/A (Horizontal or vertical, tank) (Manufacturer's serial number) (CRN) (National Board number) (Year built) (Drawing number) 5. ASME Code, Section VIII, Division 1 2013/ N/A N/A N/A [Edition and Addenda, if applicable (date)] (Special service per UG-120(d)) (Code Case numbers) 6. Shell: 0.75" SA240 304 0 in N/A N/A (Material spec. number, grade) (Nominal thickness) (Corr. allow.) (Inner diameter) [Length (overall)] Body Flanges on Shells Bolting Flange How No. Type ID OD Min Hub Thk Material Location **Bolting** Washer (OD, ID, Washer Attached Num & Size Thk Material thk) Material N/A C=.20 7. Seams: Corner Joint N/A N/A N/A N/A N/A N/A N/A [Long. (welded, dbl., sngl., lap, butt)] [R.T.(spot or full)] (Eff.,%) (H.T. temp) [Girth. (welded, dbl., sngl., lap, butt)] [R.T. (spot or full)] (No. of courses) (Time, hr) (Eff., %) 8. Heads: (a) Material (b) Material SA240 304 SA240 304 (Spec. no., grade) (Spec. no., grade) Location (Top, Bottom, Minimum Corrosion Crown Radius Knuckle Radius Elliptical Ratio Conical Hemispheri Flat Diameter Side to Pressure (Convex or Ends) Thickness Allowance Apex Angle cal Radius Concave) TOP, BTM 0.375" N/A N/A N/A N/A N/A 4" x 96.125' N/A (a) (b) **ENDS** 0.375' n N/A N/A N/A N/A N/A 4" x 5.875' N/A Body Flanges on Heads Bolting Min Hub Bolting Material Washer (OD, Location Type ID OD Flange Thk Material How Attached Washer Material Num & Size Thk ID, thk) (a) N/A at max. temp. 125 psi N/A 300 °F 9. MAWP N/A (Internal) (External) (Internal) (External) Min. design metal temp. -20 °F at 125 psi Hydro, pneu., or comb. test pressure HYDRO. at 172 psi Proof test N/A 10. Nozzles, inspection and safety valve openings: Material Nozzle Thickness Attachment Details Purpose (Inlet, Outlet, Diameter or Reinforcement Location (Insp. No. Type Drain, etc.) Size Material Open.) Nozzle Flange Nom. Corr. Nozzle Flange IN/OUT 2 3" 150#RFWN SA312 TP304 SA182 F304 SCH-80 Weld Welded Welded Header 2 1" Weld **AUX CPLG** SA182 F304 6000# Welded Welded Nozzle AUX 2 1" **CPLG** SA182 F304 6000# Weld Welded Welded Header 0.75" SA182 F304 6000# Weld **AUX** 1 **CPLG** Welded Welded Header Other Structure Attached NO Lugs N/A Legs N/A Bolted

11. Supports: Skirt (Number) (Where and how) (Yes or no) (Number) (Describe)

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors, have been furnished for the following items of the report:

N/A

(Name of part, item number, Manufacturer's name and identifying stamp)

Line 6 - -Tube and Plug Dimensions OR Header Dimensions: 6.625" X 0.75" X 8' 0.125"

Straight length of tubes, OR, Distance between the headers: 16' 0.0"

(A) TUBES: 250 x 0.625" OD, Gauge: 18BWG, Material: SA249 304L Rolled Tube Sheet (B) INSP.OPENINGS: 500, Type: 3/4x16UNF-Threaded, Material: 316SS (C)IMPACT REQUIREMENTS: IMPACT

UHA-51. Constructed in conformance to Appendix 28. EXEMPT PER:

FORM U-1A (Back)

NB Number 92259

conform to the ASME		CERTIFICATE OF SHOP/FIELD de in this report are correct and that all dD PRESSURE VESSEL CODE, Section 017	etails of design, mater		
Date 12/09/2015	Co. name	Harsco Industrial Air-X-	Changers	Signed	Jul Cooper
		(Manufacturer)			(Representative)
CERTIFICATE OF SHOP/FIELD INSPECTION					
		Harsco Industrial Air-X-Changers commission issued by The National Boa	at <u>5615 South 129th E. Ave., Tulsa, Oklahoma, 74134</u> I Board of Boiler and Pressure Vessel Inspectors and employed by		
OneCIS Insurance Company, of Lynn, MA					
have inspected the component described in this Manufacturer's Data Report on and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.					
Date12/09/2	015 Sig	ned Quarterized in Medicin	Commissions		672A, OK765 ard (incl. endorsements)]

2427800 exe: v6.3.110 Form and version: U1A-18